

National Water Supply & Drainage Board
Chemical Quality of Water - June 2010
For Schemes over 5000 connection

RSC - Western South

Region	Scheme	No. of Samples Tested	No. of Samples satisfactory	Reason for unsatisfactory & action taken
Kalutara	Kalutara	13	13	
	Aluthgama	7	7	
	Payagala	3	3	
	Wadduwa	3	3	
	Beruwala	4	4	
Total		30	30	

Region	Scheme	No. of Samples Tested	No. of Samples satisfactory	Reason for unsatisfactory & action taken
Kegalle	Mawanella	1	1	
Total		1	1	

Region	Scheme	No. of Samples Tested	No. of Samples satisfactory	Reason for unsatisfactory & action taken
HORANA / PANADURA	Dehiwala	15	15	
	Moratuwa	18	18	
	Panadura	13	13	
Total		46	46	

Region	Scheme	No. of Samples Tested	No. of Samples satisfactory	Reason for unsatisfactory & action taken
Bandarawela	Badulla	13	13	
Total		13	13	

RSC - Western North

Region	Scheme	No. of Samples Tested	No. of Samples satisfactory	Reason for unsatisfactory & action taken
Gampaha	Negombo	20	20	
Total		20	20	

Region	Scheme	No. of Samples Tested	No. of Samples satisfactory	Reason for unsatisfactory & action taken
Monaragala	Wellawaya	8	8	
Total		8	8	

Region	Scheme	No. of Samples Tested	No. of Samples satisfactory	Reason for unsatisfactory & action taken
Towns North Central	Wattala	10	10	
	Kelaniya	8	8	
	Mahara	3	3	
	Ja-Ela	2	2	
Total		23	23	

RSC- North Central / North

Region	Scheme	No. of Samples Tested	No. of Samples satisfactory	Reason for unsatisfactory & action taken
Anuradhapura	Anuradhapura	3	3	
Total		3	3	

RSC - Central

Region	Scheme	No. of Samples Tested	No. of Samples satisfactory	Reason for unsatisfactory & action taken
Kandy South	Gampola	1	1	
	Udu/Yatinuwara	1	1	
Total		2	2	

RSC-North Western

Region	Scheme	No. of Samples Tested	No. of Samples satisfactory	Reason for unsatisfactory & action taken
Puttalam	Puttalm	6	3	1. NH3= 0.78mg/l, 2.NH3=0.42mg/l, at Dis system 3. NH3=0.6mg/l, at distribution system ,Full treatment is proposed under ADB
	Chillaw	1	1	
Total		7	4	

Region	Scheme	No. of Samples Tested	No. of Samples satisfactory	Reason for unsatisfactory & action taken
Kandy East	Haragama	1	1	
	Kundasale WSS	1	1	
	Balagolla WSS	1	1	
Total		3	3	

Region	Scheme	No. of Samples Tested	No. of Samples satisfactory	Reason for unsatisfactory & action taken
Kandy North	Akurana	1	1	
	Wegiriya	1	1	
	Matale	1	0	Colour=96, Turbidity=19.7, Mn=0.1, Partial Treatment is proposed under GOSL
	Polgolla/Balangoda	1	1	
Total		4	3	

RSC- Sabaragamuwa/Uva

Region	Scheme	No. of Samples Tested	No. of Samples satisfactory	Reason for unsatisfactory & action taken
RATNAPURA	Ratnapura	7	7	
	Embilipitiya	6	6	
Total		13	13	

RSC- Southern

Region	Scheme	No. of Samples Tested	No. of Samples satisfactory	Reason for unsatisfactory & action taken	
Galle	Galle WSS	0	0		
	Ambalangoda	1	1		
	Hapugala	1	1		
	Hkkaduwa	2	2		
	Akmeemana	1	1		
	Bope/Poddala	0	0		
Balapitiya	1	1			
Total		6	6		

Region	Scheme	No. of Samples Tested	No. of Samples satisfactory	Reason for unsatisfactory & action taken
Matara	Weligama	2	2	
	Matara	1	1	
Total		3	3	

RSC - East

Region	Scheme	No. of Samples Tested	No. of Samples satisfactory	Reason for unsatisfactory & action taken
Ampara	Kalmunai	2	2	
	Sainthamaruthu	1	1	
	Akkaraipattu	2	2	
	Ampara	13	13	
	Samanthurei	9	9	
Total		27	27	

Region	Scheme	No. of Samples Tested	No. of Samples satisfactory	Reason for unsatisfactory & action taken
Hambantota	Ambalantota	2	2	
	Hungama/ Ranna	2	2	
	Hambantota	0	0	
	Kataragama	2	2	
	Tangalle	1	1	
	Lunugamvehera	1	1	
total		8	8	

Region	Scheme	No. of Samples Tested	No. of Samples satisfactory	Reason for unsatisfactory & action taken
Trincomalee	Trincomalee	2	2	
Total		2	2	